

10 or 15 Year Warranty Design Summary

"The name trusted in roofing since 1906"



EPDM – Ballasted

All products specified for this roofing system must be manufactured or approved by Mule-Hide Products Co. This criteria is limited to buildings of 75' in height or less.

Membrane / Adhesive Type / Other

1. 0.045" or 0.060" thick Mule-Hide EPDM: Standard Black
2. Field seams: 3" In-Seam Tape & Primer (10 or 15 year warranty)
3. Field seams: Max 10-Year Warranty - Splice Adhesive with Membrane Cleaner/Tape Primer
4. All 'T' joints overlaid with EPDM uncured flashing tape.

Deck Type

1. Any roof deck capable of supporting the weight of a Ballasted System may be used.
2. The determination that the roof deck can support the required additional loads shall be the responsibility of the building owner/owner's representative.

Slope Requirement/Drainage

1. Positive drainage required (no ponding 48 hours after a rain)
2. 1/4" per horizontal foot preferred
3. 1/8" slope with sufficient number of drains and crickets/saddles may be considered
4. Maximum roof slope of 2:12

Construction Type

1. New Construction
2. Reroof – Full tear off of existing roofing down to deck
3. Recover – Over existing roofing system or existing insulation (all wet materials removed)

Insulation/Overlayment*

Insulation Type or Overlay
Approved Polyisocyanurate - Min 1" thick - Min 18 psi
Approved Extruded Polystyrene - Min 3/4" - Min 15 psi
Approved Expanded Polystyrene - Min 1" - Min 1 lbs density
HD Fiberboard - Min 1/2" thick- Installed over Approved Insulation

*NOTES:

1. Thicknesses stated are for single layer of material.
2. Consult Specification Manual for list of approved insulations for use under overlayment.
3. Insulation must be loose-laid over an approved substrate.
4. Mechanical attachment of insulation is not permitted.
5. Roof insulation may be spot attached with an approved insulation adhesive to facilitate installation. Requires prior approval from Mule-Hide.
6. System warranties require the use of Mule-Hide labeled components, products supplied by Mule-Hide or approved in writing by Mule-Hide prior to the start of the project.

10 or 15 Year Warranty Design Summary

EPDM – BALLASTED

Ballast Requirements

Building Height	Ballast Requirements
Up to 25'	#2 Stone @ 13#/SF for 10' wide perimeter #4 Stone @ 10#/SF for field of roof
26' to 50'	#2 Stone @ 13#/SF for 20' corners #2 Stone @ 13#/SF for 10' wide perimeter #4 Stone @ 10#/SF for field of roof
Over 50'	Mule-Hide recommends the use of a interlocking ballast paver system

Concrete Pavers

1. Minimum Size: 2' x 2' x 2"
2. Minimum Weight: 22 pounds per square foot
3. Membrane Protection: Rubber or plastic pedestals, or 4" x 4" sections of Mule-Hide Walkway Pads.
4. Paver type must be submitted to Mule-Hide for approval prior to bid.

Metal Accessories

1. All Metal copings, gravel stops, fascia, and drip aprons must be installed according to Mule-Hide approved details.
2. Conventional metal edge details that require flanges to be 'stripped in' must use Cured Cover Tape.
3. All Metal Scuppers must have welded (soldered) seams.
4. Metal accessories provided by Mule-Hide will be included in Standard and Premium System warranties.

Other Requirements

1. No 'As-Built' projects. All projects are to be reviewed and approved prior to installation.
2. Shop drawings must include all pertinent details.
3. Contact Mule-Hide Technical Department for specific code requirements such as Factory Mutual (FM) or Underwriters Laboratory (UL).
4. Rubber walkway pads can not be used within 10' of the roof perimeter for buildings exceeding 50' in height.

NOTES:

1. **These are enhancements to the Mule-Hide EPDM Ballasted System Specification, as written in the Mule-Hide EPDM Specification Manual. Refer to Mule-Hide EPDM Specification Manual for complete specification and details.**
2. **The information contained in this document is general information. Requirements may be different for each specific job based on the conditions of each building. Always contact Mule-Hide Technical Department to review the specific job conditions prior to bidding the project.**