

20-Year Warranty Design Enhancements

"The name trusted in roofing since 1906"



PVC Fleece Back – Fully Adhered

Revision Date: May 14, 2019

All products specified for this roofing system must be manufactured or approved by Mule-Hide Products Co. This criteria is limited to buildings of 100' in height or less.

Membrane / Adhesive Type / Other

1. Minimum 60-mil Mule-Hide Reinforced PVC Fleece Back or minimum 50-mil PVC KEE HP Fleece Back.
2. Mule-Hide Helix® Max Low-Rise Adhesives, Aqua Base 120 or HydroBOND water based PVC Bonding Adhesive
3. All 'T' joints overlaid with PVC Non-Reinforced Flashing membrane and heat-welded on all sides. See detail MHP-115B.
4. Field/Wall seam transitions must be overlaid with PVC Non-Reinforced Flashing Membrane with heat welded seams. See detail MHP-115C
5. All End Laps must be stripped in with 6" wide reinforced PVC. See Detail MHP116.
6. Base flashing can be flashed with Standard (non-fleece back) membrane.
7. All field seams must be heat welded.

Deck Type / Typical Fastener - Refer to Specifications for minimum pullout criteria.

Standard Roof Deck (4)	Insulation Fastener (1)	Insulation Plate
Steel (22 gauge or heavier)	Mule-Hide DP (#12)	Mule-Hide 3" Metal Stress Plates
Structural Concrete (3,000 psi)	Mule-Hide HDP (#14) (2)	Mule-Hide 3" Metal Stress Plates
Plywood (Min 15/32" thick)	Mule-Hide DP (#12)	Mule-Hide 3" Metal Stress Plates
Wood Plank (Min 1-1/2" thick)	Mule-Hide DP (#12)	Mule-Hide 3" Metal Stress Plates
Fibrous Cement & Gypsum (2)(3)	TL Fasteners by Tru-Fast	3" Galvalume Insulation Plate by Tru-Fast

Notes:

1. Heavier gauge fasteners may be required to meet Factory Mutual or code requirements.
2. Other fasteners may be considered, submit request to Mule-Hide prior to bidding.
3. Pullout testing is required, must exceed 300 pounds with TL Fastener.
4. Contact Mule-Hide Technical Department for other roof decks or non-standard roof decks.

Slope Requirement/Drainage

1. Positive drainage required (no ponding 48 hours after a rain)
2. 1/4" per horizontal foot preferred
3. 1/8" slope with sufficient number of drains and crickets/saddles may be considered

Construction Type

1. New Construction
2. Reroof – Full tear off of existing roofing down to deck
3. Recover – Over existing roofing system or existing insulation (all wet materials removed and verification by a Independent 3rd party moisture scan)

Insulation/Overlayment - Mechanical Attachment into Standard Roof Decks*

Insulation Type or Overlay	Fasteners per 4' x 8' board		
	Field	Perimeter	Corner
Approved Polyisocyanurate - Min 2" thick (top layer)	8	12	16
Approved Polyisocyanurate - Min 1.5" up to 2" thick ³	12	18	24
½" HD Poly-Iso - Installed over Approved Insulation	16	24	32
HD Fiberboard - Min 1/2" thick- Installed over Approved Insulation	16	24	32

Note: HydroBond is not approved for use on HD Fiberboard

20-Year Warranty Design Enhancements

PVC Fleece Back – FULLY ADHERED

Insulation/Overlayment - Mechanical Attachment into Standard Roof Decks* (continued)			
Dens Deck Prime or Securock - Min 1/4" thick - Installed over Approved Insulation	12	18	24
OSB - Min 7/16" thick - Installed over Approved Insulation	17	25	32
Approved OSB/Polyisocyanurate Composite - Min 2" thick	17	25	32

*NOTES:

1. Gypsum board or suitable base sheet may be approved as needed to meet required fire code.
2. Consult Specification Manual for list of approved insulations for use under overlayment.
3. Contact Mule-Hide Technical Department for Polyisocyanurate less than 1.5" in thickness.
4. Certain codes may require additional fastening requirements.
5. System warranties require the use of Mule-Hide labeled components, products supplied by Mule-Hide or approved in writing by Mule-Hide prior to the start of the project.

Insulation/Overlayment - Adhesive Attachment

1. **Mule-Hide Helix® Max Low-Rise Adhesive.** Refer to the specifications and appropriate Helix® Max Product Data Sheet for acceptable insulations, substrates, and bead spacing.

Metal Accessories

1. All Metal copings, gravel stops, fascia, and drip aprons must be installed according to Mule-Hide approved details.
2. Conventional metal edge details that require flanges to be 'stripped in' must be construction from PVC coated sheet metal and stripped in with PVC membrane. All seams are to be heat-welded.
3. All Metal Scuppers must be constructed of PVC clad metal, have welded (soldered) seams with a continuous flange. See detail MHP-136.
4. Metal accessories provided by Mule-Hide will be included in System warranties.

Other Requirements

1. No 'As-Built' projects. All projects are to be reviewed and approved prior to installation.
2. Shop drawings must include all pertinent details.
3. Contact Mule-Hide Technical Department for specific code requirements such as Florida NOA, Factory Mutual (FM) or Underwriters Laboratory (UL).

Warranty Wind Speed (Maximum Peak Gusts)

Wind speed coverage for a specific project will vary depending on a variety of factors, including the deck type, fastening density, location, height of the roof, and edge details.

Contact Mule-Hide Technical Department for specific requirements.

NOTES:

1. This is a summary of the Mule-Hide PVC Fully Adhered System Specification, as written in the Mule-Hide PVC Specification Manual. Refer to Mule-Hide PVC Specification Manual for complete specification and details.
2. The information contained in this document is general information. Requirements may be different for each specific job based on the conditions of each building. Always contact Mule-Hide Technical Department to review the specific job conditions prior to bidding the project.