



NOTES:

1. REFER TO SPECIFICATIONS FOR FLASHING MEMBRANE REQUIREMENTS.
2. LAPS IN FLASHING MUST BE OFFSET FROM LAPS IN FIELD SHEET.
3. CAP SHEET MUST BE HEATED AND GRANULES EMBEDDED IN SURFACE AT ALL LAPS OVER GRANULATED SURFACES WHEN INSTALLING THE CAP SHEET.
4. MAXIMUM FLASHING HEIGHT FOR APP MODIFIED BITUMEN FLASHINGS IS 36". IF WALL IS TALLER THAN 36", SEE DETAIL MHMB-UN-CW06T
5. SINGLE PLY MEMBRANE MUST OVERLAP TOP OF MODIFIED BITUMEN FLASHING PRIOR TO INSTALLING A/P BAR.
6. ALL VERTICAL SURFACES AT APP FLASHINGS TO BE PRIMED.
7. IF FLASHING SUBSTRATE IS COMBUSTIBLE, REFER TO DETAIL MHMB-UN-CW11T OR MHMB-UN-CW02T.

**MULE-HIDE  
PRODUCTS CO., INC.**

**HIGH WALL  
PARAPET FLASHING  
SYSTEMS:**

**APP MODIFIED BITUMEN**

**DETAIL NO.:**

**MHMB-UN-CW06T**

REVISION DATE: MARCH 2015