



NOTES:

1. REMOVE ALL LEAD AND OTHER FLASHING BEFORE INSTALLING FIELD FABRICATED PIPE SEAL.
2. ON MECHANICALLY FASTENED SYSTEMS, INSTALL A MINIMUM OF FOUR (4) 2.4" SEAM PLATES AROUND PROJECTIONS WITH A DIMENSION UP TO 6". ADDITIONAL SEAM PLATES WILL BE REQUIRED FOR PROJECTIONS WITH DIAMETERS GREATER THAN 6" AND SHALL BE SPACED 12" ON CENTER MAX.
3. FASTENERS AND SEAM PLATES ARE NOT REQUIRED ON ADHERED SYSTEMS UNLESS PROJECTION DIAMETER EXCEEDS 18".
4. APPROXIMATELY 1/8" DIAMETER BEAD OF CUT-EDGE SEALANT IS REQUIRED ON CUT EDGES OF PVC REINFORCED MEMBRANE.
5. SQUARE TUBING WRAP IS NOT TO BE USED AS A PITCH PAN.

**MULE-HIDE  
PRODUCTS CO., INC.**

**PREFABRICATED SQUARE TUBING WRAP**

**SYSTEMS:  
ALL PVC SYSTEMS**

**DETAIL NO.:**

**MHP-144**

REVISION DATE: 1/2016