



NOTE:

1. WOOD NAILERS EXTENDING DOWN TO THE ROOF DECK ARE REQUIRED BELOW THE MEMBRANE WHEN THE ANTICIPATED WEIGHT PER SQUARE INCH (PSI) OF THE UNIT EXCEEDS 80% OF THE RATED COMPRESSIVE STRENGTH OF THE ROOF INSULATION.

**MULE-HIDE
PRODUCTS CO., INC.**

**SLEEPER
DETAIL**
**SYSTEMS:
ALL TPO SYSTEMS**

DETAIL NO.:
MHT-UN-620
REVISION DATE: 03/2017